

IBM Switched and Monitored PDU

5/8/2013

New part numbers

IBM released new part numbers for these PDUs.

See the table below for the old and new numbers.

The latest firmware for the original part numbers is v01.2_1.

The latest firmware for the new part numbers is v01.3_1.

The option part numbers have stayed the same.

IBM PDU									
Delta Part#	Option	IBM PN	NEW IBM PN	IBM FRU	NEW IBM FRU	Program Name	NEW PDU KIT	NEW EC#	Remarks
AD-380/32AA	46M4002	43V6143	46W1607	46M4014	46W1611	1U (Rack)	00AK102	N32463E	9 C19 & 3 C13 (unattached line cord) - 3 phase WYE: 16/32 Amp; Single phase: 24/32/48/63 Amp)
AD-208/48AA	46M4003	43V6144	46W1608	46M4015	46W1612	1U (Rack)	00AK103	N32463E	9 C19 & 3 C13 (attached line cord) - 3 phase Delta: 48 Amp
AD-380/32BA	46M4004	43V6145	46W1609	46M4016	46W1613	1U (Rack)	00AK104	N32463E	12 C13 (unattached line cord) - 3 phase WYE: 16/32 Amp; Single phase: 24/32/48/63 Amp
AD-208/48BA	46M4005	43V6146	46W1610	46M4017	46W1614	1U (Rack)	00AK105	N32463E	12 C13 (attached line cord) - 3 phase Delta: 48 Amp